



**Centrum stavebního inženýrství a.s. Praha,**  
**Centre of Building Engineering Prague, Laboratory in Prague**  
Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Certifikační orgán  
Accredited Test Laboratory, Authorised Body, Notified Body, Certification Body  
Pražská 16, 102 21 Praha 10, The Czech Republic

## EC-CERTIFICATE OF CONFORMITY

**1390 – CPD – 0072/07/P**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

***Factory made mineral wool products ROCKWOOL used for thermal insulation of buildings***  
***(trade marks and type codes according to EN 13 162 are given in the annex to the certificate )***

placed on the market by : **ROCKWOOL Polska, Sp.z o.o.**  
**ul. Kwiatowa 14**  
**66-131 Cigacice, Poland**

and produced in the factory : **ROCKWOOL Polska, Sp.z o.o.**  
**ul. Kwiatowa 14**  
**66-131 Cigacice, Poland**  
**(production lines CIG 1, CIG 2, CIG 3, CIG 4)**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body 1390 - Centrum stavebního inženýrství a.s. - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control .

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

**EN 13 162 : 2008**

**and Annex B and C of the standard EN 13 172: 2008**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on < 21. 12. 2007 > and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Notified Body 1390  
Prague, 29. 07. 2010



Ing. Petr Kučera, CSc.  
Deputy of Notified Body 1390



**Centrum stavebního inženýrství a.s. Praha,**  
**Centre of Building Engineering Prague, Laboratory in Prague**  
Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Certifikační orgán  
Accredited Test Laboratory, Authorised Body, Notified Body, Certification Body  
Pražská 16, 102 21 Praha 10, The Czech Republic

**Annex to the EC-Certificate of Conformity 1390-CPD-0072/07/P**  
**The certificate covers the following products of ROCKWOOL Polska, Cigacice factory:**

Trade mark	Thermal conductivity W/mK	Reaction to fire	Type code according to EN 13 162
DOMROCK	0,045	A1	T1-WS-WL(P)-MU1
ROCK-ROLL			
MATA W			
ROCKMIN	0,039	A1	T2-WS-WL(P)-MU1
MULTIROCK			
ROCKBATTS			
STALROCK			
PLYTA z WELNY MINERALNEJ FLIZROCK			
SUPERROCK(d=40-49)	0,035	A1	T2-WS-MU1
SUPERROCK(d=50-99)	0,035	A1	T2-WS-AW 0,75-MU1
SUPERROCK(d=100-220)	0,035	A1	T2-WS-AW1,00-MU1
ROCKBATTS SUPER	0,034	A1	T2-WS- MU1
TOPROCK	0,035	A1	T2-WS- MU1
ROCKTON(d=30-49)	0,036	A1	T3-CS(10)0,5-WS-MU1
ROCKTON(d=50-99)	0,036	A1	T3-CS(10)0,5-WS-AW 0,75-MU1
ROCKTON(d=100-200)	0,036	A1	T3-CS(10)0,5-WS-AW 0,95-MU1
ROCKTON F	0,036	A1	T3-CS(10)0,5-WS-MU1
INDUSTRIAL F50			
PANELROCK	0,036	A1	T3-CS(10)0,5-WS- MU1
INDUSTRIAL 50			
INDUSTRIAL 60			
PANELROCK F	0,036	A1	T3-CS(10)0,5-WS- MU1
INDUSTRIAL F60			
INDUSTRIAL F80			
STALROCK MAX F			
VENTI MAX F			
PANELROCK 80	0,036	A1	T3-CS(10)0,5-WS- MU1
INDUSTRIAL 80			
STALROCK MAX			
BLOCZEK TRAPEZOWY			
VENTI MAX			
WENTIROCK MAX	0,037	A1	T4-CS(10)10-TR7,5-WS- MU1
WENTIROCK (d= 20-79)			
WENTIROCK (d= 80-200)	0,037	A1	T4-CS(10)10-TR7,5-WS- AW 0,95-MU1
WENTIROCK F	0,037	A1	T4-CS(10)10-TR7,5-WS- MU1
INDUSTRIAL F100			
INDUSTRIAL F120			
FASROCK MAX (d=80-100)	0,039	A1	T4-DS(TH)-CS(10)10-TR7,5-WS- MU1
FASROCK MAX (d=110-200)	0,037	A1	
FASROCK XL	0,042	A2	T5-DS(TH)-CS(10)Y)40-TR100-WS- MU1
CB ROCK	0,038	A1	T4-DS(TH)-TR7,5-PL(5)100-WS- MU1




**Centrum stavebního inženýrství a.s. Praha,**  
**Centre of Building Engineering Prague, Laboratory in Prague**  
Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Certifikační orgán  
Accredited Test Laboratory, Authorised Body, Notified Body, Certification Body  
Pražská 16, 102 21 Praha 10, The Czech Republic

TARMONTROCK	0,045	A1	T4-CS(10\Y)70-TR120-WS- MU1-SS50
SANDWICHROCK			
SANDWICH BATTS CB			
BLOCZEK PW LAMELLA	0,045	A1	T5-CS(10\Y)70-TR120-WS- MU1- SS50
MONROCK MAX (d=40-79)	0,040	A1	T4-DS(TH)-CS(10)40-TR7,5-PL(5)350-WS-WL(P)- MU1
MONROCK MAX (d=80-200)	0,039	A1	T4-DS(TH)-CS(10)40-TR7,5-PL(5)400-WS-WL(P)- MU1
DACHROCK MAX (d=40-79)	0,041	A1	T4-DS(TH)-CS(10)50-TR15-PL(5)400-WS-WL(P)- MU1
DACHROCK MAX (d=80-200)	0,040	A1	T4-DS(TH)-CS(10)50-TR15-PL(5)500-WS-WL(P)- MU1
DACHROCK MAX HARD (d=40-79)	0,042	A1	T4-DS(TH)-CS(10)70-TR15-PL(5)400-WS- MU1
DACHROCK MAX HARD (d=80-200)	0,042	A1	T4-DS(TH)-CS(10)70-TR15-PL(5)500-WS- MU1
SPODROCK (d=20-180)	0,039	A1	T4-DS(TH)-CS(10)30-TR7,5-PL(5)300-WS-WL(P)- MU1
INDUSTRIAL 120 (d=20-180)			
DACHROCK	0,041	A1	T4-DS(TH)-CS(10)70-TR15-PL(5)450-WS-WL(P)- MU1
DACHROCK KSP			
DACHROCK SP			
KLIN DACHOWY			
STROPROCK	0,041	A1	T6-CS(10)50-PL(5)400-WS- CP4-MU1
FLOOR BATTS	0,042	A1	T4-CS(10)80-TR15-PL(5)700-WS-WL(P)-MU1
DACHROCK 185			
LAMROCK	0,045	A1	T5-DS(TH)-CS(10\Y)80-TR150-WS-WL(P)-MU1-SS70
LAMROCK MAX			

Notified Body 1390  
Prague, 29. 07. 2010



  
Ing. Petr Kučera, CSc.  
Deputy of Notified Body 1390